DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: [redacted] BILL LACKEY APPLICANT: MARTY TUCKER
ADDRESS: 392 DOVER RD APPLICATION DATE: 2-12-01 DATE EVALUATED: _____
PROPOSED FACILITY: HOUSE PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 50
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	6% [redacted] LSS	0-8"	scl, wk, gr	fr, ss, sp, sc<p		>48"			PS .3
		8-32"	c, med, sbk	fr/fi, ss, sp, sc<p					
		32-48"	scp mix c, med, sbk	fr, ss, sp, sc<p					
2	6% [redacted] LSS	0-8"	scl, wk, gr	fr, ss, sp, sc<p		>48"			PS .3
		8-32"	c, med, sbk	fi/fr, s, p, sc<p					
		32-48"	c, med, sbk	fr, ss, sp, sc<p					
3	4% LSS	0-6"	scl, wk, gr	fr, ss, sp, sc<p		>48"			PS .3
		6-28"	c, med, sbk	fi/fr, s, p, sc<p					
		28-48"	c, med, sbk	fr, ss, sp, sc<p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	GRA ✓ 25% RED	GRA-1 25% RED
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: JACK MORE, SAMMY DEAL