IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR T & T Company DATE Jan. 8, 1987 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hayside Estates Lot 2 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	.4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	None observed

Lot Area 100' X 200'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public (✓)

150' of 16" T & J Panels

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Robert C. Price J. C. Moore DATE Jan. 8, 87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold