5

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR [redacted] T+T Co. DATE 3-5-87 PERMIT NO. _____

PHONE: Business _____ Home Jim Rabit

LOCATION Wayside Estates Lot 24 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey
Percolation Rate 35
Topography 2-10 %
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area 1/2 acre

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines _____
Sq. Ft. _____ near Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (✓)
180' 16 T+J Panel

Installed by Donald Lachey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-5-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold