DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: [illegible]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kenneth Robinson APPLICANT: ___
ADDRESS: 134 Red Walnut Dr Statesville APPLICATION DATE: 6-14-99 DATE EVALUATED: 6-25-99
PROPOSED FACILITY: 3bdrm DW PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.5Ac
LOCATION OF SITE: Joe R Brotherson to Red Walnut on Right Next To #134 PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 3-5%	0-19	SBK C	F,	Gray @ 14"				P.S. .3
		19-48	SBK C SAP Inclusion	F, FS					
		~~48+~~	~~SBK~~	~~C~~					
2	L 5-8%	0-48	SBK C 7.5YR 5/6	F, FR	Gray				P.S .25
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [illegible] Potter
OTHER(S) PRESENT: Owner