02460

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sherrill Faw DATE 12/14/84 PERMIT NO.

PHONE: Business Home

LOCATION 70E, Rt on Bethesda, Lf on Moose Cav Meadows Lot at End.

SUBDIVISION NAME Moose Cav Meadows LOT NO. 9A SECTION OR BLOCK NO. S. R. No.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes ( ) No ( )
Lot Area 1/2 acre +

Character & Porosity of Soil Clay
Percolation Rate 3 gal/sq ft/day
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations None

_____ Basement with Plumbing ___✓___ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 4
No. of Lines
Sq. Ft. 1200+ Linear Ft. 400+
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Jack Stroud

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Jack Moore, RS

COMMENTS: Keep well 50' minimum from any part of the system.

CERTIFICATE OF COMPLETION BY Jack Moore RS DATE 12/14/84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White / Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold