DIVISION OF ENVIRONMENTAL [illegible]

COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: T+T OWNER: AGENT: PHONE: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

PROPOSED FACILITY: _____

PROPERTY SIZE: _____

LOCATION OF SITE: T+T oak creek lot 34m

WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1957/ 1966 SAPRLT CLASS.	HORIZ LTAR
1	linear 12%	0 to 6	L GR		PS	PS	PS	N/A	.3
		6 to 20	C SBK	SEAP SS SP					
		20 to 36	H:CL SBK	SEAP SS SP					
2	linear 12%	0 to 6	L GR		PS	PS	PS	N/A	.3
		6 to 36	C SBK	SEAP SS SP					
3									
4									
5									

AVAILABLE SPACE (1945): _____ SITE CLASSIFICATION (1950): _____ SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY: _____ OTHER(S) PRESENT: _____

COMMENTS: lot is bisected by Drainage ways
Cuts down on available space
will have to use space saving systems