IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders Inc DATE 10/14/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bell Rd #2316 – to Bell Wood

S. R. No. _____


SUBDIVISION NAME Bellwood LOT NO. 20 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Loyd Soil	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	ok	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Front	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ok	
			Rock or other impervious formations	ok	

Lot Area 20,000



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hope Bros, Statesville Concrete material

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Lowery DATE 10/14/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold