IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

REPAIR
OWNER OR CONTRACTOR RHETTA HOUSE DATE 6/3/91 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION 70E, TL BELL RD BEFORE BELLWOOD TL
PRIVATE RD, AT END ON (R) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other REPAIR


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations EXISTING

Lot Area AMPLE

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 570 Linear Ft. 190
Depth of Stone in Lines 12"
Water Supply: Individual (✓) WELL
Public ( )

Installed by AAA ENTERPRISES

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. MOORE

COMMENTS: — LINE SHORTENED BY 10' DUE TO PROPERTY LINE.

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 6/3/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold