13167

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR T+T Inc DATE 7-29-91 PERMIT NO. 5K-A-21pt

PHONE: Business _____ Home _____

LOCATION 70E TR Bethesda TL at Red oak at office S. R. No. _____

SUBDIVISION NAME Wayside Est. LOT NO. _____ SECTION OR BLOCK NO. Old well lot

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Sandy clay
Percolation Rate 14
Topography 2 to 20
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area 202' X 202'

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System Public Gas line

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Tackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Well was abandon by Air Drilling Inc. Record Attached

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 7-29-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold