DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____ SHEET ____ OF ____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: T+T
ADDRESS: _____ OWNER ___ AGENT: ___ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
LOCATION OF SITE: lot 318 oak creek PROPERTY SIZE: _____
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	linear	0 to 5	L	GR				.1942 Wetness Cond. - N/A
		5 to 30	C	SBK	NEAP			.1943 Depth/.1956 Sapr. - N/A
		30 to 48	CL	weak SBK	NEAP			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
2	linear	0 to 4	L	GR				.1942 Wetness Cond. - N/A
		4 to 48	C	SBK	SEAP			.1943 Depth/.1956 Sapr. - N/A
								.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
3	linear	0 to 4	L	GR				.1942 Wetness Cond. chroma 6
		4 to 48	C	SBK	SEAP	10YR	6	.1943 Depth/.1956 Sapr. - N/A
								.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .2
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AILABLE SPACE (.1945) yes OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) PS
YSTEM TYPE _____ LONG-TERM ACCEPTANCE RATE(S) .3
VALUATED BY: J.C. moore OTHER(S) PRESENT: Jim Thabet
OMMENTS: _____