DIVISION OF ENVIRONMENTAL HEALTH

ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: T+T Inc OWNER: AGENT: PHONE:

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

PROPOSED FACILITY: Single Family

PROPERTY SIZE: 120' X 180 Lot 236

LOCATION OF SITE: Forest acres / J

WATER SUPPLY: On-Site Well ____ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY		
1	linear 8%	0+04"	L	GR		.1942 WETNESS CONDITION	N/A
		4+048"	C	SBK	li	.1943/.1955 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	linear 8%	0+04"	L	GR		.1942 WETNESS CONDITION	N/A
		4+048	C	SBK	li	.1943/.1955 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	linear 8%	0+04	L	GR		.1942 WETNESS CONDITION	N/A
		4+48	C	SBK	li	.1943/.1955 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1955 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1955 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) YES SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35

OTHER FACTORS(.1946) _____ SYSTEM TYPE: Conv. Gravity

EVALUATED BY: _____ OTHER(S) PRESENT: Tina Thabet

COMMENTS: _____

DRAFT