DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION

FOR

ON-SITE WASTEWATER SYSTEM

APPLICANT: T+T
ADDRESS: _____

APPLICATION DATE: _____ EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____

LOCATION OF SITE: Lot 215 Forest acres
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ SOIL MEASURED: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	(BC) TEXTURE	(CS) STRUCTURE	(MO) MOTTLES	
1	linear 10%	0 to 6"	L	GR		N/A
		6 to 48	C	SBK	1:1	N/A
						N/A
						PS
						.35
2	linear 10%	0 to 4	L	GR		N/A
		4 to 24	C	SBK	1:1	N/A
		24 to 36	C	weak SBK	1:1	N/A
		36 to 48	Transition			PS
						.35
3	linear 12 to 15%	0 to 4	L	GR		N/A
		4 to 36	C	SBK	1:1	N/A
		36 to 48	Transition micaceous			N/A
						PS
						.3
4						
5						

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE & SOIL SUITABILITY ACCEPTANCE RATE: .33

OTHER FACTORS(.1946) _____ SYSTEM TYPE _____

EVALUATED BY: _____ OTHER(S) PRESENT: Jim Tholut

COMMENTS: _____

DRAFT