DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: T + T OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: Forest acres I lot 218
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	Linear 4%	0 to 4"	L	Gr		.1942 WETNESS CONDITION	N/A
		4 to 36	C	56K	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 48		Transition		.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	Linear 4%	0 to 4	L	Gr		.1942 WETNESS CONDITION	N/A
		4 to 42"	C	56K	1:1	.1943/.1956 SAPROLITE	N/A
		42 to 48"		Transition		.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	Linear 5 to 6%	0 to 4"	L	Gr		.1942 WETNESS CONDITION	N/A
		4 to 48	C	56K	1:1	.1943/.1956 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): ~~PS~~ PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) _____ SYSTEM TYPE ~~_____~~ Conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Jim Thaler
COMMENTS: _____

DRAFT