IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Alton Box Board Co. DATE 10-3-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Industrial Park Highway 70 E.

S. R. No. 702.

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (X) Other _____

No. Bedrooms X No. Bathrooms 4

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No (X)

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area Acreage


Character & Porosity of Soil Sand Clay

Percolation Rate 10-30

Topography Level

Depth to Water Table 48"

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public ( )

Installed by Lew Lowe Bldg. Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Sanders DATE 10/3/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold