HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____ ____ . .
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: T+T OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
LOCATION OF SITE: Forest [redacted] acres PROPERTY SIZE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	2 to 4 %	0 to 6"	L	GR		.1942 WETNES CONDITION - N/A
		6 to 24"	C	SBK	1:1	.1943/.1956 SAPROLITE - 36"
		24 to 36	Transition			.1944 RESTRICTIVE HORIZON - N/A
		36" +	Saprolite			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	2 to 4 %	0 to 6"	L	GR		.1942 WETNES CONDITION - N/A
		6 to 30"	C	SBK	1:1	.1943/.1956 SAPROLITE - 31"
		30 to 37	Transition			.1944 RESTRICTIVE HORIZON - N/A
		37" +	Saprolite			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35 gal/sf/day
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: P.C. Moore OTHER(S) PRESENT: Jim Thaler
COMMENTS:

DRAFT