DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: T + T OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 7-5-94
PROPOSED FACILITY: Single Family Dwelling
PROPERTY SIZE: 1/2 acre +
LOCATION OF SITE: Lot 219 Forest Acres sec V
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINERALOGY	
1	2 to 6% linear	0 to 3"	L	GR		.1942 WETNESS CONDITION - N/A
		3 to 27"	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		27 to 48"	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	linear 2 to 4%	0 to 2	L	GR		.1942 WETNESS CONDITION - N/A
		2 to 30"	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		30 to 48"	Transition			.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	linear 2 to 4%	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 24	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 48	Transition		mica in soil	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) _____ SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: R C Moore OTHER(S) PRESENT: Jim Thabet
COMMENTS: _____

DRAFT

0U2483