07297

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR E.J. Donaldson DATE 12-6-89 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Corner Broadmoor & Camden Rd

S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 353 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Clayey


Percolation Rate 1 2 3 4 5 6 slow

Topography 2 to 4%

Depth to Water Table 6'+

Rock or other impervious formations Nothing to 6'+

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 gal S.T. 1000 gal M.T. Gals.

Nitrification Field:

No. of Lines _____

Sq. Ft. _____ Linear Ft. _____

Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

300' 16" TFJ Panel
Pressure Lateral

Installed by James Hunter

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Wire Pump & Alarm according to State Elec. Code

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 12-6-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold