IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kent Milstead DATE 11-22-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION St. Andrews Rd

S. R. No. _____


SUBDIVISION NAME Shannon Acres LOT NO. 346 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Large +

Character & Porosity of Soil Appling clay + white mosling clay
Percolation Rate 120 min +
Topography 4% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 7
Sq. Ft. 1025 Linear Ft. 375
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: The Soil is very Poor for percolation + appears almost impervious. It is the opinion of this inspector that an improvements permit should not have been issued on this lot. (Approved on construction only)

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 11-22-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold