IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Anderson Mewell DATE 27 Nov 74 PERMIT NO.

PHONE: Business Home

LOCATION Deanville Ave.

SUBDIVISION NAME Statesville Country Club LOT NO. 304 SECTION OR BLOCK NO. S. R. No.


House ( ) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 33,750

Character & Porosity of Soil Yellow Clay
Percolation Rate 87 Min Per
Topography Slight Slope to Right of Home
Depth to Water Table ---
Rock or other impervious formations ---



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10" plus
Water Supply: Individual (✓)
Public ( )

Installed by Stone Key - Robert Hyde

500 gal Tank
144 linear ft
360 sq ft
16" Stone
} Basement Fixtures + washing machine

IMPROVEMENTS PERMIT BY

COMMENTS: Very poor soil on syste for basement Fixtures - Some good soil on last 6' of line but evidence of water table in first 30".
Yellow clay for main syster and no sign of water table - Tight yellow clay.
Drain all surface water and gutter drains away from syste for syste.-

CERTIFICATE OF COMPLETION BY John T Hassell DATE 7 Nov 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold