IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Wells DATE 4-12-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Deanville Rd

S. R. No. _____

SUBDIVISION NAME Hanna Acres LOT NO. 302 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____


Character & Porosity of Soil Clay Loam

Percolation Rate 2-6"6 Slow

Topography Gently Sloping

Depth to Water Table Under 4 Feet

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 6

Sq. Ft. 1134 Linear Ft. 378

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 4/12/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold