IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Carl Johnson DATE 12/16/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Deaverville Rd

SUBDIVISION NAME Shannon Acres S. R. No. _____

LOT NO. 287 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 150 X 150


Character & Porosity of Soil CFC

Percolation Rate med

Topography 6-8% Slope

Depth to Water Table unk

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 990 Linear Ft. 330

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Johnson Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Lowry DATE 12/16/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold