IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard E. Sansom Jr. DATE 10-13-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. TR on St. Andrews TR on Sedgefield 300' on left.

SUBDIVISION NAME Shannon Acres S. R. No. _____ LOT NO. 284 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 4

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Cecil clay loam


Percolation Rate 5 gal/sq. ft/day

Topography 2 to 6% slope

Depth to Water Table 10'+

Rock or other impervious formations none

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by Paul Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: R. C. Moore DATE 10-13-81

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold