## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Black DATE 4/6/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St. Exit., T.R. on St. Andrews, house on Rt _____ S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 282 SECTION OR BLOCK NO. _____

House ( ✓ ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes | ( ✓ ) | No | ( ) |
| Auto. Dishwasher | Yes | ( ✓ ) | No | ( ) |
| Auto. Wash. Machine | Yes | ( ✓ ) | No | ( ) |
| Site Suitable | Yes | ( ✓ ) | No | ( ) |

Lot Area 206 X 176 approx


Character & Porosity of Soil Cecil Clay

Percolation Rate 55 min approx

Topography 2-6% slope to Up

Depth to Water Table unk

Rock or other impervious formations none observed




Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 16"

Water Supply: Individual ( ✓ )
Public ( )

Installed by Robert Hoke
Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 4/6/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold