IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Johnson Bldg. Co. Jerry Hankins Jr. DATE 12-23-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 54 Andrews Rd.

S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 330 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 125 x 276 approx


Character & Porosity of Soil CSE CSDL

Percolation Rate 1-00

Topography Slopes to Back

Depth to Water Table High water table

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 300 Linear Ft. 300

Depth of Stone in Lines 14" extra stone

Water Supply: Individual (✓)

Public ( )

Installed by Wes Lytton

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic Tank System constructed in suit matter, water is drainfield at time of Inspection. Owner is aware of conditions. All drainage from house gutters etc. to be diverted away from drainfield.

CERTIFICATE OF COMPLETION BY Steven Ford DATE 12/23/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold