IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C.L. Stamey DATE 1 July 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Statesville Country Club - St. Andrews Rd.

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. # 256 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Grave - Silt	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	1" - Comp	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slop	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk	
			Rock or other impervious formations	unk	

Lot Area approx ¾ acre



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hall Septic Tank

System for basement
Tank - 1000
Lines - 3
Sq. Ft. - 625
Linear ft. 250
Depth of Stone - 10"

IMPROVEMENTS PERMIT BY _____

COMMENTS: Distribution box not on concrete slab and water leaked. Very poor soil in system I end of lines - deep. Presently good soil for main system.

CERTIFICATE OF COMPLETION BY Tommy Edwards DATE 1 July 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold