IREDELL COUNTY HEALTH DEPARTMENT

→ Danny Hearn

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR 2 Nolan Boan DATE 4-16-90 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Setzfield

S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 245 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 1 acre

Character & Porosity of Soil Clayey
Percolation Rate 3
Topography 2+2b30
Depth to Water Table 44"+to 52"
Rock or other impervious formations Weathering 36"

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System Street

1500 S.T.

Size of Tank 1500 P.T. Gals.

Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )
200' T+J Panel

Installed by Dennit Young

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Wire pump & Alarm on separate circuits according to Rockell Co. Bldg Insp Standards Landscape & Pipe Outlet so that surface water does not stand over S.T. System

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 4-16-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold