IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR L.L. Collins DATE 7 Mar 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Statesville County Club Sigfield Rd.

S. R. No. _____


SUBDIVISION NAME Statesville County Club. LOT NO. 250 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 plus	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Rear of Lot	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	wet	
			Rock or other impervious formations	ok	

Lot Area 30,000 plus



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1284 Linear Ft. 428
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Herbie Lasley

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Tolerand DATE 7 May 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold