IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hunter Homes, Inc DATE 8/4/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION St. Cloud Drive

S. R. No. _____


SUBDIVISION NAME Shannon Acres LOT NO. 222 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Prov. Suitable

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area _____

Character & Porosity of Soil Cecil Clay
Percolation Rate Slow - mod
Topography 2-6% slope
Depth to Water Table mk
Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 16
Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 8/4/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold