IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders Inc. DATE 8-18-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bell Road

S. R. No. _____


SUBDIVISION NAME Bellwood LOT NO. 22 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Fair-Med
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	15% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ample
			Rock or other impervious formations	Hayes Rock

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 250 Linear Ft. 300

Depth of Stone in Lines 18"

Water Supply: Individual (✓)

Public ( )

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd Jr. DATE 8/18/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold