IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders Inc. DATE 6-2-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bell Rd

S. R. No. _____

SUBDIVISION NAME Bellewood LOT NO. 23 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____ Res. Lizella

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area _____

Character & Porosity of Soil Loam
Percolation Rate Ley. Mary
Topography 10-15% Slope
Depth to Water Table none
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 846 Linear Ft. 282
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 6/2/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold