9756

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herman Warsham DATE 9-18-89 PERMIT NO. B-15

PHONE: Business _____ Home _____

LOCATION Bell Rd Turn on Farmwood Dr at 1st on Rt.

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2+ obj
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10+
			Rock or other impervious formations	none

Lot Area .87 acres

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 360 Linear Ft. 315
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by WCS Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY F. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY F. C. Moore DATE 9-18-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold