IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harold A. Munday DATE 4/8/74 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 64 E. Rd on Bell Rd at Beams Store - go 3/4 to 1 Mile Mobile Home behind brick House S. R. No 2316

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	mpi
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope To Back
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	mpi
Lot Area Average			Rock or other impervious formations	—



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines _____
Water Supply: Individual (✓)
Public ( )

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Ford Jr. DATE 4/8/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold