IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Peoples DATE 5-31-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Off Bell Road - Kaywood Dr.

S. R. No. _____

SUBDIVISION NAME Bellwood LOT NO 26-27 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area _____


Character & Porosity of Soil CuC - LuE

Percolation Rate Slow

Topography Slopes to Branch

Depth to Water Table very

Rock or other impervious formations Layer Rock



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hall Septic Tank Serv.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Layer rock and smell type soil - suggest limited water usage.

CERTIFICATE OF COMPLETION BY [signature] DATE 5/31/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold