IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Barnhardt DATE 7/17/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bell Rd

SUBDIVISION NAME Bellwood LOT NO. 57 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1.9 acres


Character & Porosity of Soil sapling & saprolite

Percolation Rate 120 min/inch

Topography 6-10%

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

existing

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 405 Linear Ft. 135

Depth of Stone in Lines 18-20" + 10"

Water Supply: Individual ( )

Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 7/17/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold