IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James F. Bankhead DATE 7 July 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64 E to Bell Rd. Go across rail to Hollowood Sub-division Lot on left appx 4 mi. Lot # 57 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Home and Mobile Home

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area appx 1½ acres

Character & Porosity of Soil Red sand
Percolation Rate same
Topography 1-2 & 5%
Depth to Water Table ok
Rock or other impervious formations Red sand entire drainfield



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 480
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hole Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Red Hole sand throughout entire system - could not use pole hole auger - had to dig - pole ok

CERTIFICATE OF COMPLETION BY [illegible] DATE 7 July 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold