IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gilbert Bowles DATE 10-14-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bellwood - Off Bell Rd

S. R. No. _____


SUBDIVISION NAME Bellwood LOT NO. 55 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Good
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Rolling Front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none
			Rock or other impervious formations	none

Lot Area Acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by D. Brown Mooresville

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 10/14/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold