## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tim Roper DATE 3-29-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Kaywood Dr _____ S. R. No. _____


SUBDIVISION NAME Beewood LOT NO. Tract H 34 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 6.33 Acres

Character & Porosity of Soil LUE
Percolation Rate See
Topography Slope To Rt.
Depth to Water Table 4ft
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 250 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS Excavation of basement and driveway diverted to B.T. area creating a silt problem. Very wet area - Care should be Taken to water usage - Part of system covered at time of inspection (Builder Home)

CERTIFICATE OF COMPLETION BY Gilliam Taylor Jr. DATE 3/29/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold