IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR United Builders Inc. DATE 4-11-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION left E. TR on Bus Rd #2316 cross creek TR into Bellwood 1st St. Rt House on Rt. S. R. No. _____


SUBDIVISION NAME Bellwood LOT NO. 53 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	C Fc 2	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Fair	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'	
			Rock or other impervious formations	none	

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 150 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Taylor DATE 4/14/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold