IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G.S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Little & Sons DATE 6-22-82 PERMIT NO. 82

PHONE: Business _____ Home _____

LOCATION Deaton Rd. SR


SUBDIVISION NAME Shannon Acres LOT NO. 42 S. R. No. _____

House ( ) Mobile Home ( ) Business ( ) Other _____ SECTION OR BLOCK NO. _____

No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil Clayey
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate 27
Auto. Wash. Machine	Yes ( )	No ( )	Topography Slope
Site Suitable	Yes ( )	No ( )	Depth to Water Table 18"
Lot Area 3/4 AC + sewer easement on Club property			Rock or other impervious formations None

Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 1000 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public ( )

Installed by Little Septic

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D. Moore

EXISTING SYSTEM CHECKED BY: _____ DATE 6-30-82

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold