IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charlie S. Dockery DATE 9-24-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St. TR on Augusta Dr. TL on Deauville Rd 1/4 mi on rt. S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 155 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 1½

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area ½ acre+

Character & Porosity of Soil Clayey
Percolation Rate 4
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by AAA Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 9-24-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold