APPENDIX H

EDELL COUNTY HEALTH DEPARTMENT

SITE EVALUATION

(Ground Absorption Sewage Disposal)

ER: Nolton Boan DATE REQUESTED: _____

RESS: _____ PLAT NO.: _____

NTY: Iredell LOT SIZE: Approx 1 acre

ATION OF SITE: lot 109 Shannon Acres

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
SLOPE (%)	(S) PS U 2 to 6 %	S PS U	S PS U	S PS U
SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 clay)	S (PS) U loamy	S PS U	S PS U	S PS U
SOIL STRUCTURE (12-36 in.) (Clayey soils)	S (PS) U Blocky	S PS U	S PS U	S PS U
SOIL DEPTH (In.)	S (PS) U 36"+	S PS U	S PS U	S PS U
RESTRICTIVE HORIZONS (In.) (Impervious Strata, rock)	(S) PS U none observed	S PS U	S PS U	S PS U
SOIL DRAINAGE/GROUNDWATER (External & Internal)	S (PS) U Good External Fair Internal	S PS U	S PS U	S PS U
SOIL PERMEABILITY (Percolation Rate)	S (PS) U 80 to 100 min/inch	S PS U	S PS U	S PS U
OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
SITE CLASSIFICATION*	Provisionally suitable.			
SOIL SERIES				

S - Suitable PS - Provisionally Suitable U - Unsuitable

ee Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)

ommendations/Comments: Class III soils .5 gal/sq' /day application rate.

cribed By: L. C. Moore R.S.

Title: Sanitarian III Date: 4-15-83

Form 2601 (2/77)
itation