## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Johnson Bldg Co. DATE 5-14-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Westwith St.

S. R. No. _____

SUBDIVISION NAME Shannon Acres LOT NO. 100 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes | (✓) | No | ( ) |
| Auto. Dishwasher | Yes | (✓) | No | ( ) |
| Auto. Wash. Machine | Yes | (✓) | No | ( ) |
| Site Suitable | Yes | (✓) | No | ( ) |

Lot Area 20,000 +


Character & Porosity of Soil Red clay

Percolation Rate 60

Topography Slope to Rt Side (Shannon)

Depth to Water Table 10

Rock or other impervious formations None




Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Wes Lytton

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Taylor DATE 5/24/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold