IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hendren Bldg. Co. DATE 7-19-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St. Ext.

SUBDIVISION NAME Camelot Acres S. R. No. _____

LOT NO. 20 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 134 X 136


Character & Porosity of Soil Red Clay

Percolation Rate Satisfactory

Topography 2-6% Slope

Depth to Water Table Unknown

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 405 Linear Ft. 300

Depth of Stone in Lines 18"

Water Supply: Individual ( )

Public (✓)

Installed by Ellis Yount & Son

IMPROVEMENTS PERMIT BY Wm Howard

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Todd DATE 7/19/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold