IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George mahaffey DATE 9-12-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad st. TL on Camalot Drive 1st enterance 1/4 mi on right S. R. No. _____


SUBDIVISION NAME Camalot Acres LOT NO. 66 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 ✓

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	120 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 1/2 acre +



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: Grade lot + Pipe Gutters so that water will not stand over Tank or lines.

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 9-12-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold