IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jenkins Bldg. Co. DATE 2-23-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Bond St. Ext. Tk on 1st Driveway in Crescent Acres

S. R. No. _____

SUBDIVISION NAME Crescent Acres LOT NO. 65 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____


Character & Porosity of Soil Clay Br

Percolation Rate Fair - Med

Topography Level to Gently Slope

Depth to Water Table Unk

Rock or other impervious formations None



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 990 Linear Ft. 330

Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Young & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox DATE 2/25/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold