IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald V Grant DATE 8 04 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Camelot Acres off East Broad St. Ext. _____

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. # 18 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 21,468 sq ft

Character & Porosity of Soil C/B2
Percolation Rate 60 per
Topography Level
Depth to Water Table approx 50'
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 930 Linear Ft. 312
Depth of Stone in Lines 10'
Water Supply: Individual ( )
Public (✓)

Installed by Yoder Trucking

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Will Edwards DATE 8/6/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold