IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edgar Cransill DATE 8-29-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E Broad St Ext.

S. R. No. _____


SUBDIVISION NAME Camelot Acres LOT NO. 61 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	CS B>	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Serv to Mod	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	none	

Lot Area 20,000 Sq'



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey

IMPROVEMENTS PERMIT BY Glenn Fox Jr.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 8-29-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold