IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR D. Baker DATE 13 Sept 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Statesville County Club - N. Archers Dr.

S. R. No. _____

SUBDIVISION NAME Hamm Acres LOT NO. # 106 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 37,000 sq ft


Character & Porosity of Soil Red Clay Loam. Cecil Clay

Percolation Rate 60

Topography Slight Slope 6 feet

Depth to Water Table ok

Rock or other impervious formations ok



Plot of System S. Archers Dr.

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 927 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Henry Lyons

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W. M. Howard DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold