IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rev Frank R. Campbell DATE 16 Oct 73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Statesville Country Club – St. Andrews Rd. 1st white house past Glen Eagles Rd S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 148 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 32,900 sq ft

Character & Porosity of Soil Red Clay
Percolation Rate None
Topography Slight Slope
Depth to Water Table None
Rock or other impervious formations None



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1080 Linear Ft. 360
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Herbie Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE 16 Oct 73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold