IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eges Cranfill DATE 3-29-78 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION E. Broad St Ext.

SUBDIVISION NAME Emmalet Acres S. R. No. _____

LOT NO. 6 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 19,259.5


Character & Porosity of Soil Clay

Percolation Rate Slow - Med

Topography Rolling Slope

Depth to Water Table Unk

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field.

No. of Lines 3

Sq. Ft. 780 Linear Ft. 330

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Hobe Septic Tank Serv.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Ford Jr. DATE 3/29/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold